	Name of Project: 1450 Elford					
	Location: Victoria , BC					
Item						2022-07-28 BCBC Reference
1	BCBC 2018 Part 3					DUDU Relefence
	Project Description: -					
2	Major Occupancy(s): Group A - Divition 2 & Group C					3.1.2.1 (1)
3	Building Area: 136 sq.m.					1.4.1.2 (A)
4	Bldg Floor Area:267 sq.m.U/G Parking Area0 sq.m					1.4.1.2 (A)
5	Number of Storeys: 2					1.4.1.2[A]; 3.2.1.1
6	Height of Building (m): 7m (Average Grade to top of Roof level)					-
7	Number of Streets/Access Routes: 1					3.2.2.10; 3.2.5.4
8	Building Size, Construction, Occupancy: Group C, up to <3> Storey, Sprinklered or Unsprinkalered					3.2.2.53 & 5.2.2.25
9	Sprinkler System Proposed:					3.2.2.53
10	Standpipe Required:		Yes	🖂 No		3.2.5.8
11	Fire Alarm Required:	X	Yes	🗆 No		3.2.4
12	Water Service/Supply is Adequate: 🛛 Yes (assumed) 🗆 No					3.2.5.7
13	High Building:		Yes	🖂 No		3.2.6
14	Permitted Construction:Image: CombustibleImage: Non-CombustibleImage: BothActual Construction:Image: CombustibleImage: Non-CombustibleImage: Both					3.2.2.53 & 5.2.2.25
	Exterior Wall Cladding:					
15	Mezzanine(s) Area: N.A.					3.2.1.1
16	Occupant Load Based On:⊠ m²/person□ Sleeping RoomsTotal Occupant Load Group C (9.3 sq.m/person)267 sq.m28.7= personsTotal Occupant Load Group A - Divition 2 (4.6 sq.m/person)267 sq.m58.0= x persons					3.1.17
17	Barrier-Free Design:	⊠ Yes	🗆 No			3.8
18	Hazardous Substances:	□ Yes	⊠ No	N.A.		3.3.1.2
19	Required Fire Resistance Rating	Horizontal Assemblie FRR (Hours)		3.2.2.25	Listed Design No. or Description	3.2.2.53 & 5.2.2.25
	(FRR)	Roof	45 min	N/A	See Assemblies	
		Floors	45 min	45 min	(TBD)	
		FRR of Supporting Floor over Crawl	45 min N/A	45 min N/A		

Code notes:

Occupancy Of The Building Is

During the day Group A, Division 2 - Schools and colleges, nonresidential

During the night Group C - Dormitories (Residential Occupancies)

The building size, construction type, and Fire Resistance Rateing of the existing building meet the major occupancies of Group A2 and C.

There is an existing Fire Alarm System and smoke detectors linked to alarms.

The Fire Alarm System and smoke detectors are monitored by Telus.

1450 Elford St. Code


## **ATTACHMENT B**









2022534










## 1450 Elford St. Lower Floor Plan













1450 Elford St. Main Floor Plan

